

Model No: PHAZCAB

PRATT MANIFEST CABINET

In accordance with all state Dangerous Goods Storage and Handling Regulations, it is a requirement to provide a manifest of dangerous goods when quantities exceed "Manifest Quantity" limits as stated in Schedule 2 in the Regulations.

The manifest must be kept on the premises in a place that is easily accessible to the emergency services authority with information on the quantity, type and location of dangerous goods stored and handled on the premises to enable them to respond appropriately if called to an incident.

The manifest should be housed in a holder of substantial weatherproof construction located near the Outer Warning Placard at the front of the premises.

The Pratt Manifest Cabinet provides a safe and dry enclosure for the manifest documents and complies with these Regulation requirements.

The cabinet features:

- A weather resistant channel around the door frame to prevent rainwater egress.
- Elevated galvanised steel document binder holder.
- 003 combination key lock, compatible with emergency services.

The manifest must include:

- Name & address of occupier and contact details.
- Summary list of dangerous goods at the premises.
- Information on Bulk storage other than IBCs.
- Information on packaged goods & IBCs.
- Information about dangerous goods in manufacture.
- Dangerous goods in transit.
- A plan of the premises.

External : 600mm H x 500mm W x 150mm D

Construction : Galvanised Steel

Finish : Powder-coated Paint Finish

